

GOVERNMENT OF TELANGANA
ABSTRACT

I&CAD Dept. – Modification of MDDL from (+)357.500M to (+)355.900M for Mission Bhageeratha Drinking Water supply scheme under Gaddennavagu medium Irrigation Project in order to supply water to 14000Acr ayacut – Orders – Issued.

IRRIGATION AND CAD (WRG-GRC) DEPARTMENT

G.O.Rt.No. 215

Dated: 23-08-2024

Read the following:

- 1) G.O.Rt.No.885, Irrigation and CAD (WRG-GRC) Department, Dt.30.10.2017
- 2) From the Engineer-in-Chief(General), Hyderabad, Lr. No.ENC(G)/Dy. ENC(G)/DCE(G.B)/DEE1/AEE1/MED-GVP/2024, Dt:08.02.2024.

&&&&

ORDER:

In the G.O 1st read above, Government have issued orders duly fixing the Minimum Draw Down Level (MDDL) at 357.50 M for Gaddennavagu Project and allocated 0.55 TMC for Mission Bhagiratha per annum.

2. In the reference 2nd read above, the Engineer-in-chief (General), Hyderabad, has requested the Government to accord permission for modification of MDDL from(+)357.500M to (+)355.900M for Mission Bhageeratha Drinking Water supply scheme under Gaddennavagu medium Irrigation Project, in order to supply water to 14000Acr ayacut.

3. Government after careful examination, hereby modify the designated MDDL to be maintained for Mission Bhagiratha from (+)357.500M to (+)355.900M for Mission Bhageeratha Drinking Water supply scheme under Gaddennavagu medium Irrigation Project, in order to supply water to 14000Acr ayacut.

4. The Engineer-in-Chief(General), Hyderabad shall take necessary action accordingly.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF TELANGANA)

RAHUL BOJJA
SECRETARY TO GOVERNMENT

To

The Engineer-in-Chief(General),Hyderabad.

Copy to:

All the Chief Engineers in the State through the Engineer-in- Chief (General), Errumanzil, Hyderabad.

All the District Collectors.

The P.S. to Hon'ble Minister.

The P.S. to Chief Secretary.

The P.S. to Secretary, I&CAD Dept.

// FORWARDED :: BY ORDER//

SECTION OFFICER